



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY**  
**REGION 8**  
**999 18<sup>TH</sup> STREET- SUITE 200**  
**DENVER, CO 80202-2466**  
**Phone 800-227-8917**  
**<http://www.epa.gov/region08>**

Ref: ENF-W

**CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**

Charisse Haws, Registered Agent  
Bar-B-Bar Meadows Home Owners Association  
P.O. Box 3345  
Jackson, WY 83001

Re: Administrative Order Addendum  
Docket No. SDWA-08-2005-0035  
PWS ID #5601439

Dear Ms. Haws:

This addendum to the Administrative Order issued July 11, 2005 to Bar-B-Bar Meadows incorporates the schedule for treatment and modification completion outlined in the May 31, 2006 letter from Brian Lenz at Jorgensen Associates on behalf of the Bar-B-Bar Meadows Home Ownership Association. This letter constitutes the written approval by EPA of the Bar-B-Bar Meadows Home Owners Association's actions that have been or will be completed before July 31, 2006.

The System exceeded the MCL for total coliform bacteria in February and March 2006. EPA acknowledges that the System has already complied with many items in the compliance plan. The following schedule lists the action to be taken, deadline date and completion date if applicable.

Action	Deadline	Completion
Disinfect water storage tank and distribution system.	March 30, 2006	March 10, 2006
Take eight repeat samples for coliform bacteria following disinfection, per EPA request by Charla Colson	March 30, 2006	March 13, 2006
Take five routine samples in the month following a positive	April 30, 2006	April 4, 2006

coliform

Issue public notice to the water system users regarding the MCL violations in 2006	May 5, 2006	May 5, 2006
Remove any vegetation from within three feet of the well heads and inspect well heads for damage once snow has melted.	May 15, 2006	May 9, 2006
Install a raised rim, with sealed lid, around water storage tank access hatch, to prevent runoff and debris, rodents and bugs from entering into the storage tank.	June 30, 2006	June 2, 2006
Take five routine samples each month through July 2006.	May 31, 2006 June 30, 2006 July 31, 2006	May 2, 2006 June 20, 2006

Please contact Kimberly Pardue Welch, at (303) 312-6983 if you have any questions concerning this Addendum.

Sincerely,

**SIGNED**

Diane L. Sipe, Director  
Technical Enforcement Program  
Office of Compliance, Enforcement,  
and Environmental Justice

**SIGNED**

David J. Janik, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Brian Lenz, Jorgensen Associates

Christopher Leigh, Bar-B-Bar Meadows  
WY DEQ (via email)  
WY DOH (via email)